

## **Indoor Vehicle Displays**

When motorized vehicles are to be displayed during an event, the PNE shall be notified in advance. Events with displayed motorized vehicles shall comply with the following:

1. Vehicles shall not be started or operated within any assembly building during show hours. Repair of display vehicles is prohibited within any assembly building.
2. All fuel tank openings shall be locked or sealed in an approved manner. Where it is not feasible to lock or seal the opening, the fuel tank shall be empty and the vehicle towed into position.
3. Batteries shall be disconnected. Fuel-electric hybrid vehicles shall be safeguarded to prevent operation of the vehicle.
4. Adding or removing fuel on site is prohibited (must be done outdoors).
5. Vehicle fuel shall not exceed one quarter (25%) of the tank capacity or 20L whichever is less.
6. No "Armor All" or any oil based tire cleaner is to be sprayed on vehicles before entry or while on display in assembly buildings.
7. Oil pan to be placed underneath the vehicles.
8. Carpet or like material must be placed underneath each tire to protect the floor.
9. Vehicles must be situated so there is a minimum 10-foot corridor on every side of the display.

Vehicles powered by Liquid Propane Gas (LPG) are permitted in assembly buildings subject to complying with all the following City of Vancouver By-laws:

1. The propane fuel tank is permanently installed,
2. fuel system is equipped with an automatic stop-fill valve,
3. fuel cut-off valve is closed,
4. fuel tank filling connections are locked or secured against tampering, and
5. batteries are disconnected.

In addition, permanently installed propane systems (not for vehicle fuel) in recreational vehicles, boats, trailers and similar exhibited products shall be empty of propane prior to entering any display building.